



15'-8"  
 Bedroom 1  
 TL Heat loss @ 60F = 7941  
 TL Heat loss @ 70F = 9370  
 TL Heat loss @ 80F = 10641  
 TL Heat loss @ 90F = 11911  
 TL Heat loss @ 100F = 13182

Bedroom 2  
 TL Heat loss @ 60F = 7363  
 TL Heat loss @ 70F = 8688  
 TL Heat loss @ 80F = 9866  
 TL Heat loss @ 90F = 11044  
 TL Heat loss @ 100F = 12222

12'-6"  
 Bedroom 3  
 TL Heat loss @ 60F = 6094  
 TL Heat loss @ 70F = 7190  
 TL Heat loss @ 80F = 8165  
 TL Heat loss @ 90F = 9140  
 TL Heat loss @ 100F = 10115

Bedroom 4  
 TL Heat loss @ 60F = 4203  
 TL Heat loss @ 70F = 4960  
 TL Heat loss @ 80F = 5633  
 TL Heat loss @ 90F = 6305  
 TL Heat loss @ 100F = 6978

Office  
 86 sq. ft.

Wet room  
 TL Heat loss @ 60F = 1977  
 TL Heat loss @ 70F = 2332  
 TL Heat loss @ 80F = 2649  
 TL Heat loss @ 90F = 2965  
 TL Heat loss @ 100F = 3282

Bathroom  
 TL Heat loss @ 60F = 2598  
 TL Heat loss @ 70F = 3066  
 TL Heat loss @ 80F = 3482  
 TL Heat loss @ 90F = 3898  
 TL Heat loss @ 100F = 4313

Laundry  
 TL Heat loss @ 60F = 2019  
 TL Heat loss @ 70F = 2382  
 TL Heat loss @ 80F = 2706  
 TL Heat loss @ 90F = 3029  
 TL Heat loss @ 100F = 3352

Upstairs total

TL Heat loss @ 60F = 32195  
 TL Heat loss @ 70F = 37988  
 TL Heat loss @ 80F = 43142  
 TL Heat loss @ 90F = 48232  
 TL Heat loss @ 100F = 53444