



REQUIRED BILL OF MATERIALS (BOM)

DESCRIPTION	QUANTITY
PRESSURE RELIEF VALVE (90 PSIG)	1
L4006B AQUASTAT W/WELL (OVER-TEMP CONTROL)	1
L4006A AQUASTAT W/WELL (CIRCULATOR CONTROL)	1
L4006B AQUASTAT W/WELL (OIL BOILER CONTROL)	1
3-SPEED CIRCULATOR PUMP W/ISOLATION FLANGES	1
TERMOVAR MIXING VALVE (THREE-WAY)	1
BALANCING VALVE (BALL-VALVE)	1
1" AUTOMAG ZONE VALVE W/TRANSFORMER (24VAC)	2
WEIGHTED CHECK VALVE (FLOW CHECK)	1
SWING CHECK VALVE	2
EXPANSION TANK (AMTRIL 60)	1
CENTRAL AIR SEPARATOR	1
FEEDWATER PRESSURE REGULATOR	1
DRAIN VALVE	1
ISOLATION VALVE (BALL-VALVE)	5
COPPER/IRON FITTINGS AND TUBING/PIPE	LFT (AS-REQUIRED)

TARM BIOMASS SOLID PLUS 40 - PLUMBING SCHEMATIC (12/08/2011 - REV. 3)